

SKALA 1:10

[illegible]

znak bezpieczeństwa
"Przycisk alarmowy"
wym. 150x200 mm

znak bezpieczeństwa
"Główny wyłącznik prądu"
wym. 150x200 mm

ręczny ostrzegacz
pożarowy,
98x98 mm

ręczny przycisk
głównego wyłącznika
prądu, 115x115 mm

zawór odcinający

znak bezpieczeństwa
"Hydrant wewnętrzny"
wym. 150x150 mm

hydrant wewnętrzny
DN25 wnekowy
z węzłem półsztywnym
o długości
30 m,
o zasięgu rzutu
prądu gaśniczego
wody 3 m

obudowa hydrantu:
panel akustyczny
płyta MDF fornirowana,
brzoza. gr. 17 mm,
przyklejona do wewnętrznej
obudowy ze stali DC01,
gr. 1 mm

rama hydrantu
ze stali
nierdzewnej

Technical drawing of a rectangular box. The overall dimensions are 78 (width) and 18 (height). The top flange has a thickness of 6. The bottom flange has a thickness of 8. The side walls have a thickness of 8. The internal components include a central assembly with a circular feature labeled $\phi 4,5$ and a smaller circular feature labeled 4. The drawing shows a cross-section of the box with internal components and dimensions.

Technical drawing of a fire cabinet (szafka przeciwpożarowa) showing front and top views with dimensions and component labels.

Front View Dimensions:

- Overall width: 78
- Overall height: 135
- Top panel width: 15
- Top panel height: 20
- Distance from top panel to main body: 5
- Distance from top panel to main body (bottom): 9,8
- Distance from top panel to main body (right): 8,2
- Distance from top panel to main body (left): 7
- Distance from top panel to main body (bottom-left): 5,66
- Distance from top panel to main body (bottom-right): 10,61
- Distance from top panel to main body (bottom-center): 9,8
- Distance from top panel to main body (bottom-right-center): 5,41
- Distance from top panel to main body (bottom-right-center): 9,01
- Distance from top panel to main body (bottom-right-center): 5
- Distance from top panel to main body (bottom-right-center): 78
- Distance from top panel to main body (bottom-right-center): 5

Top View Dimensions:

- Overall width: 78
- Overall height: 135
- Distance from top panel to main body: 5
- Distance from top panel to main body (bottom): 9,8
- Distance from top panel to main body (right): 8,2
- Distance from top panel to main body (left): 7
- Distance from top panel to main body (bottom-left): 5,66
- Distance from top panel to main body (bottom-right): 10,61
- Distance from top panel to main body (bottom-center): 9,8
- Distance from top panel to main body (bottom-right-center): 5,41
- Distance from top panel to main body (bottom-right-center): 9,01
- Distance from top panel to main body (bottom-right-center): 5
- Distance from top panel to main body (bottom-right-center): 78
- Distance from top panel to main body (bottom-right-center): 5

Labels:

- znak bezpieczeństwa "Przycisk alarmowy" wym. 150x200 mm
- ręczny ostrzegacz pożarowy, 98x98 mm
- zawór odcinający
- znak bezpieczeństwa "Hydrant wewnętrzny" wym. 150x150 mm
- hydrant wewnętrzny DN25 wnekowy z węzłem półsztywnym o długości 30 m, o zasięgu rzutu prądu gaśniczego wody 3 m

- całość prac należy wykonać zgodnie z zasadami sztuki budowlanej, obowiązującymi przepisami sanitarnymi, BHP i p.poż., obowiązującymi polskimi normami, normami branżowymi, instrukcjami producentów oraz obowiązującymi warunkami wykonania i odbioru robót.

The diagram shows a grey rectangular building labeled 'A' on the left. A horizontal line connects it to a larger, darker grey structure labeled 'B' on the right. The word 'Rozbudowa' is written vertically between the two structures. A north arrow is located in the bottom left corner.

DATA: styczeń 2018	NR RYSUNKU: D-24.1
--------------------	--------------------